


BOARD OF COMMISSIONERS

OSBORN NESBITT, SR., CHAIRMAN
Sherri L. Washington, Commissioner Post I
Dr. Doreen Williams, Commissioner Post II



DEPARTMENT OF FINANCE

MICHELLE IRIZARRY, CFO
TELEPHONE: 770-278-7555
FACSIMILE: 770- 278-8910

Addendum No. 2

ITB No. 23-22

**ROCKDALE WATER TREATMENT PLANT REMOVAL, INSTALLATION &
REBUILD OF 2 HIGH SERVICE PUMPS & MOTORS**

October 30, 2023

ITB #23-22 hereby amended as follows:

1. Below are questions received and corresponding answers:

A. Question: Inspect impeller for wear and cavitation and repair. How much cavitation damage should we assume these impellers have? Repairing severe cavitation damage on a large impeller would add significantly more cost to the job than minor damage from wear and tear.

Answer: We are aware that there could be more damage inside the pumps/motors. Other pumps have had minor impeller cavitation damage. ITB states "Report any additional required machining or repairs of pump or motor to Rockdale Water plant management" This should include pricing for the repairs needed.

B. Question: Perform machining of pump case where needed to bring back into factory specifications. Are we to assume that this is just machining to "Clean up" the fits in the casing, or are we to assume that the casings will need a full line bore?


Answer: We do not know the extent of any damage (if any). The winner of the bid will have to determine if any machining will be needed. If extensive machining is required. It should be brought to the attention of Rockdale County water plant management with pricing to be approved.

C. Question: Perform machining or replace a) Impeller wear rings b) Case wear rings. If pump is to be line bored that would mean that the OEM Wear Rings that they have for pump 2 would no longer fit the casing and would not be able to be used.

Answer: We have the OEM parts in stock. (If they can be used). The winner of the bid will also take the OEM parts we have. If the OEM parts cannot be used, Winner will inform Rockdale County water plant management staff with a report of required work

BOARD OF COMMISSIONERS

OSBORN NESBITT, SR., CHAIRMAN
Sherri L. Washington, Commissioner Post I
Dr. Doreen Williams, Commissioner Post II



DEPARTMENT OF FINANCE

MICHELLE IRIZARRY, CFO
TELEPHONE: 770-278-7555
FACSIMILE: 770- 278-8910

and pricing to be approved by Water plant management. Any parts supplied by Rockdale County Water Plant Maintenance that are not used shall be returned to Rockdale County Water Plant Management upon completion of the repair of High Service pump #2.

D. Question: Could they verify the Sizes for the pump suction, discharge, and Impeller Diameters for both pumps?

Answer: High Service pump #2 Flowserve 200LNN600 Is 10” Suction and 8” Discharge. And the impeller size is 19.68” (See attached)

E. Question: Bid Bond: Is Rockdale County requiring that a bid bond (in the amount of five percent (5%) of the total bid amount) be submitted with this bid regardless of the dollar amount of the bid OR is Rockdale County only requiring a bid bond if the bid amount exceeds \$50,000?

Answer: Only if the total bid amount is \$50,000 or more.

F. Question: Exceptions: Is Rockdale County accepting any requested exceptions to the terms and conditions in the bid and template contract included in the bid or will any requested exceptions be rejected and/or jeopardize the potential rewarding of the bid to a bidder requesting exceptions?

Answer: Rockdale County will review any exceptions that are submitted and will make an award based on what is the most advantageous for Rockdale County.

G. Question: Warranty and/or Guaranty: It is not clear what Rockdale County is expecting from a bidder in the section below from the bid package when it states the bidder should fully explain “the condition of Warranty and/or Guaranty.” Please clarify what are the expectations. Rather than have a bidder intuit what the expectations of Rockdale County might be, could Rockdale County please state their expectations and allow the bidder to respond to them?

Answer: This was answered in Addendum No. 1, Question B.


2. All other conditions remain in full force and effect.
3. If a bid has been submitted and anything in this Addendum causes the bidder to change the item offered or to increase or decrease the bid price, the new price and/or changes will be inserted below:

BOARD OF COMMISSIONERS

OSBORN NESBITT, SR., CHAIRMAN

Sherri L. Washington, Commissioner Post I

Dr. Doreen Williams, Commissioner Post II



DEPARTMENT OF FINANCE

MICHELLE IRIZARRY, CFO

TELEPHONE: 770-278-7555

FACSIMILE: 770- 278-8910

4. All bidders under this Invitation to Bid are kindly requested to acknowledge receipt of this Addendum on page 14 of the Bid Package.

Tina Malone

Tina Malone, CPPB CPPO

Procurement Manager

Department of Finance, Purchasing Division