


2 cores were taken at Johnson Park on 07-15-2025 at 8:00 AM

Core #1

The Deck is metal
2" layer of Polyisocyanurate Insulation
1 layer of Modified bitumen Cap sheet.

Core #2

The Deck is metal
2" layer of Polyisocyanurate Insulation
1 layer of Modified bitumen Cap sheet



View of roof area where cores were taken.



Core #1



Core #2



View of repair made at Core cut. Typical of both cores