


BOARD OF COMMISSIONERS

JANICE VAN NESS, CHAIR & CEO
Tuwanya C. Smith, Commissioner Post I
Dr. Doreen Williams, Commissioner Post II



DEPARTMENT OF FINANCE

JAVAID MAJID, CFO
TELEPHONE: 770-278-7555
FACSIMILE: 770- 278-8910

Addendum No. 4

**ITB No. 25-35
HONEY CREEK & SCOTT CREEK PUMP STATIONS & FORCE MAINS**

March 13, 2026

ITB #25-35 is hereby amended as follows:

1. Below are questions received and corresponding answers:

A. Question: Section 02602 of the specifications describes the interior lining for ductile iron pipe and fittings as "Protecto 401" and "ceramic epoxy". Will Permox-CTF™ be accepted as an equal lining?

Answer: Yes

2. All other conditions remain in full force and effect.
3. If a bid has been submitted and anything in this Addendum causes the bidder to change the item offered or to increase or decrease the bid price, the new price and/or changes will be inserted below:
-
-
4. All bidders under this Invitation to Bid are kindly requested to acknowledge receipt of this Addendum on page 14 of the Bid Package.

Tina Malone

Tina Malone, CPPB CPPO
Procurement Manager
Department of Finance, Purchasing Division