

BOARD OF COMMISSIONERS

JANICE VAN NESS, CHAIR & CEO
Tuwanya C. Smith, Commissioner Post I
Dr. Doreen Williams, Commissioner Post II



DEPARTMENT OF FINANCE

JAVOID MAJID, CFO
TELEPHONE: 770-278-7555
FACSIMILE: 770- 278-8910

Addendum No. 9

ITB No. 25-35

HONEY CREEK & SCOTT CREEK PUMP STATIONS & FORCE MAINS

April 13, 2026

ITB #25-35 is hereby amended as follows:

Addendum #7, had an attachment labeled, “Exhibit in Response to Question D in Addendum #7”. It has the Revised Bid Table and this was not the correct document. The Revised Bid Table for Addendum #7 was listed twice.

Attached to this addendum is the correct document.

- 1. Below are questions received and corresponding answers: No additional questions at this time.**

A. Question: In regard to the Force Main portion of the project, we would like to confirm whether there are any segments where the installation of the force main via Horizontal Directional Drilling (HDD) would not be permitted. Additionally, if HDD is an acceptable installation method for the force main, please advise on any specific bedding or installation requirements when rock is encountered. In particular, are there conditions or requirements related to rock that would prohibit or complicate the use of HDD for this scope?

Answer: Please bid as open trench. We may consider sections of pipe to be installed via HDD installation after the project is awarded. This would only be considered as a value engineering change.

B. Question: I had a question concerning the generator for Honey and Scott Creek Pump Stations. I saw the size specifications but not a company specification, is there a specific company to be used?

Answer: Per specification section 16231-1 the following manufacturer's are approved:


- a. Cummins-Onan**
- b. Caterpillar**
- c. Kohler**

BOARD OF COMMISSIONERS

JANICE VAN NESS, CHAIR & CEO

Tuwanya C. Smith, Commissioner Post I

Dr. Doreen Williams, Commissioner Post II



DEPARTMENT OF FINANCE

JAVAID MAJID, CFO

TELEPHONE: 770-278-7555

FACSIMILE: 770- 278-8910

d. John Deere

2. All other conditions remain in full force and effect.
3. If a bid has been submitted and anything in this Addendum causes the bidder to change the item offered or to increase or decrease the bid price, the new price and/or changes will be inserted below:

4. All bidders under this Invitation to Bid are kindly requested to acknowledge receipt of this Addendum on page 14 of the Bid Package.

Tina Malone

Tina Malone, CPPB CPPO

Procurement Manager

Department of Finance, Purchasing Division